

Attestation

Italian CAM

D'ECO' SATINATO

supplied by

Sestriere vernici srl

The sample of a water-based paint was supplied to Eurofins Product Testing A/S the 28th of January 2025. The sample was tested as being representative of the manufactured product and it has been tested according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 (see the test report no. 392-2025-00041201_W_EN).

Evaluation of the emission test result according to Italian CAM Rewarding criteria:

- The relevant CMR compounds were not detectable after 28 days.
- The sum of VOC ("TVOC") after 28 days was compliance with the limit of $\leq 1000 \mu\text{g}/\text{m}^3$.
- Formaldehyde after 28 days was compliance with the limit of $< 10 \mu\text{g}/\text{m}^3$.
- Acetaldehyde after 28 days was compliance with the limit of $< 200 \mu\text{g}/\text{m}^3$.
- Toluene after 28 days was compliance with the limit of $< 300 \mu\text{g}/\text{m}^3$.
- Tetrachloroethylene after 28 days was compliance with the limit of $< 250 \mu\text{g}/\text{m}^3$.
- Xylene after 28 days was compliance with the limit of $< 200 \mu\text{g}/\text{m}^3$.
- 1,2,4-Trimethylbenzene after 28 days was compliance with the limit of $< 1000 \mu\text{g}/\text{m}^3$.
- 1,4-Dichlorobenzene after 28 days was compliance with the limit of $< 60 \mu\text{g}/\text{m}^3$.
- Ethylbenzene after 28 days was compliance with the limit of $< 750 \mu\text{g}/\text{m}^3$.
- 2-Butoxyethanol after 28 days was compliance with the limit of $< 1000 \mu\text{g}/\text{m}^3$.
- Styrene after 28 days was compliance with the limit of $< 250 \mu\text{g}/\text{m}^3$.

29 April 2025



Claus Bonde
Analytical Service Manager



Rasmus Verdier
Analytical Service Manager